

Scaffolding Daily Inspection Checklist

OK

- ___ Footings (does it have all bearing plates and mudsills if on grade)
- ___ Casters locked before work begins
- ___ Frames fully braced and plumb
- ___ Access ladder installed or separate ladder to access the scaffolding in place
- ___ Work platform fully planked at all working heights
- ___ Planking overhangs checked (no less than 6" and no more than 12")
- ___ Work platform free of clutter, mud, snow, oil, or any tripping hazard
- ___ Guardrail system in place when a worker can fall 10 feet or more
 - ___ Toprails
 - ___ Midrails
 - ___ Toeboards
 - ___ Posts
- ___ Guys, ties, supports, secured (tied vertically every 26 feet and horizontally every 30 feet)
- ___ Minimum power line clearance (10 Feet)

Competent Person _____

Time and Date _____

Job _____